

# Discharge Monitoring Report (DMR)

AR0021750 DMR SSOs February 2021

Print Date: 3/11/2021

Print Time: 9:32 am

Permit Number	Date SSO Started	Time SSO Started	Date SSO Stopped	Time SSO Stopped	Date SSO Reported	Location	Pipe Description	Manhole	Where SSO Went Into	Watershed	Type of SSO	Cause of SSO	Environmental Damage	Duration in Min.	Volume (Gallons)	Impact of SSO Incident	Steps Taken	Internal SSO ID	Web Confirmation Number	
<b>AR0021750</b>																				
AR0021750	02/01/2021	2:36 pm	02/01/2021	3:10 pm	02/02/2021	3108 S 80th St	M004-1035 to M004-1030	M004-1035	Storm Drain	Upper Little Vache Grasse Creek	Manhole	Grease	NEAH	34	340	Receiving Water (Riv, Str)	Jet Clean,,Immediate Cleanup,Disinfection Performed	21-0025	19d653ef-8455-4c0c-a46f-d1b39ae4864d	
AR0021750	02/16/2021	9:59 am	02/16/2021	12:19 pm	02/16/2021	2901 S 98th Cir	RB01-0180 to 021		Yard	N/A	Lift Station	Equipment Failure	NEAH	859	4,295	Public Land (Ground)	.,Scheduled Cleanup,No Disinfection Performed	21-0034	2cf1ebf3-9462-471b-beee-4a4fe050be0b	
AR0021750	02/17/2021	12:10 pm	02/17/2021	12:59 pm	02/18/2021	6820 Riviera Dr	M005-1030 to M005-1010		Yard	N/A	Service Line	Grease	NEAH	50	250	Private PPTY (Ground)	Power Rod,,Scheduled Cleanup,Disinfection Performed	21-0036	344f3e9e-b98b-444b-820c-85f185c87c55	
AR0021750	02/20/2021	1:38 pm	02/20/2021	2:45 pm	02/21/2021	2120 N 53rd St	S005-0730 to S005-0720		Yard	N/A	Service Line	Line Break	NEAH	67	67	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0037	afb89ff9-aecc-4482-92ed-53943aa206b8	
AR0021750	02/20/2021	5:03 pm	02/20/2021	6:14 pm	02/21/2021	6820 Riviera Dr	M005-1030 to M005-1010		Yard	N/A	Service Line	Debris	NEAH	72	360	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0038	104ea8a0-25b4-4f45-bf32-706ca242d8b0	
AR0021750	02/22/2021	4:03 pm	02/22/2021	6:10 pm	02/23/2021	3108 S 80th St	M004-1035 to M004-1030	M004-1035	Paved Area	Upper Little Vache Grasse Creek	Manhole	Debris	NEAH	127	1,270	Receiving Water (Riv, Str)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0042	8540ff91-fd1d-4fd5-855a-3c6d56dbdf4b	

**6 TOTAL OVERFLOWS**

**6,582 TOTAL GALLONS SPILLED**