

**Discharge Monitoring Report (DMR)**

AR0021750 DRM SSOs January 2021

Print Date: 2/11/2021

Print Time: 9:19 am

Permit Number	Date SSO Started	Time SSO Started	Date SSO Stopped	Time SSO Stopped	Date SSO Reported	Location	Pipe Description	Manhole	Where SSO Went Into	Watershed	Type of SSO	Cause of SSO	Environmental Damage	Duration in Min.	Volume (Gallons)	Impact of SSO Incident	Steps Taken	Internal SSO ID	Web Confirmation Number
<b>AR0021750</b>																			
AR0021750	01/11/2021	1:25 pm	01/11/2021	2:29 pm	01/11/2021	3811 N O St	S007-3350 to S007-C002		Yard	N/A	Service Line	Construction	NEAH	65	65	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0011	0c6bf499-e5bc-4afc-8d99-9649a0ebd6dd
AR0021750	01/11/2021	11:24 am	01/11/2021	3:45 pm	01/12/2021	5900 Painter Ln	WL01-0210 to WL01-0200	WL01-0210	Yard	N/A	Manhole	Line Break	NEAH	261	6,525	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0012	2e16b0b6-43c6-4840-9097-b32c70da69c1
AR0021750	01/16/2021	11:29 pm	01/17/2021	12:45 am	01/17/2021	9200 Gary St	M001-0830 to M001-0820	M001-0830	Yard	N/A	Manhole	Grease	NEAH	75	1,125	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0013	b49951c6-7cd7-479c-8cf9-1a728fad133e
AR0021750	01/18/2021	10:15 am	01/18/2021	11:15 am	01/19/2021	2115 S 65th St	S001-1040 to S001-1030		Yard	N/A	Service Line	Roots	NEAH	60	60	Private PPTY (Ground)	Repair,,Scheduled Cleanup,Disinfection Performed	21-0014	8b02c2d5-9b44-445b-9590-f93a29db1e18
AR0021750	01/18/2021	10:28 am	01/18/2021	12:59 pm	01/19/2021	6901 Dallas St	M005-0350 to M005-0340		Storm Drain, Paved Area	Massard Creek	Service Line	Grease	NEAH	152	760	Receiving Water (Riv, Str)	Jet Clean,,Scheduled Cleanup,No Disinfection Performed	21-0015	0c385b0d-15f4-4ae1-8a9f-fb94a6a11fca
AR0021750	01/21/2021	10:15 am	01/21/2021	10:44 am	01/21/2021	5200 Highland Dr	S006-1770 to S006-1760		Yard	N/A	Service Line	Line Break	NEAH	30	30	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0016	8d6f2c2d-745b-4b3a-bba4-ac8f90e95362
AR0021750	01/21/2021	10:06 am	01/21/2021	12:14 pm	01/21/2021	1426 N 56th Ter	S002-1590 to S002-1580		Yard	N/A	Main Line	Line Break	NEAH	129	645	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0017	58ef4d10-b647-4b37-8dec-ff7cfd8d9a87
AR0021750	01/24/2021	10:56 am	01/24/2021	1:44 pm	01/25/2021	2411 N 56th Ln	S005-1190 to S005-0260		Yard	N/A	Service Line	Grease	NEAH	169	338	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0018	6d8b30da-d288-4180-bd04-3e9194ae0c1a
AR0021750	01/25/2021	11:44 am	01/25/2021	12:01 pm	01/26/2021	102 N 51st St	S006-1740 to S006-1730		Building	N/A	Service Line	Line Break	NEAH	17	17	Basement Backup	Repair,,No Cleanup Performed,No Disinfection Performed	21-0021	2d7f06e6-b818-4e0a-83b3-fab9c6cb5eb9

**9 TOTAL OVERFLOWS**

**9,565 TOTAL GALLONS SPILLED**