

Discharge Monitoring Report (DMR)

AR0021750 DMR SSO March 2021

Print Date: 4/13/2021

Print Time: 10:27 am

Permit Number	Date SSO Started	Time SSO Started	Date SSO Stopped	Time SSO Stopped	Date SSO Reported	Location	Pipe Description	Manhole	Where SSO Went Into	Watershed	Type of SSO	Cause of SSO	Environmental Damage	Duration in Min.	Volume (Gallons)	Impact of SSO Incident	Steps Taken	Internal SSO ID	Web Confirmation Number	
AR0021750																				
AR0021750	03/01/2021	8:56 am	03/01/2021	9:21 am	03/01/2021	506 N 44th St	S006-1050 to S006-1040		Yard	N/A	Service Line	Line Break	NEAH	25	25	Private PPTY (Ground)	Repair,,No Cleanup Performed,No Disinfection Performed	21-0047	bafcf843-fbde-4029-93a0-a19e22de903a	
AR0021750	03/01/2021	1:20 pm	03/01/2021	8:00 pm	03/02/2021	2120 N 53rd St	S005-0730 to S005-0720		Yard	N/A	Service Line	Line Break	NEAH	400	400	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,No Disinfection Performed	21-0048	b6612883-b27c-4274-b113-8794876a9393	
AR0021750	03/02/2021	7:31 am	03/02/2021	8:45 am	03/02/2021	5103 Birnie Ave	S005-0560 to S005-0550	S005-0560	Yard	N/A	Manhole	Grease	NEAH	74	740	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0049	80bc2b1b-1120-49d4-b648-a87543a193b4	
AR0021750	03/03/2021	12:30 pm	03/03/2021	12:31 pm	03/04/2021	3941 Victory Cir	S007-0910 to S007-0900		Yard	N/A	Service Line	Line Break	NEAH	1	1	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0050	50d93747-7f54-4c96-a40e-f5b91516bf7d	
AR0021750	03/04/2021	12:59 pm	03/04/2021	1:50 pm	02/04/2021	1728 N 46th Cir	S007-0340 to S007-0335		Yard	N/A	Service Line	Grease	NEAH	50	50	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0052	725b3ba6-eccb-4efd-8a10-124d82556653	
AR0021750	03/11/2021	3:35 pm	03/11/2021	5:15 pm	03/12/2021	1913 Massard Rd	RL01-2380 to RL01-2370	RL01-2380	Yard	N/A	Manhole	Grease	NEAH	100	1,000	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0065	2db0748c-1146-4df9-b4e8-23b6fc78cdf	
AR0021750	03/17/2021	11:16 pm	03/18/2021	12:50 am	03/18/2021	2200 S 70th St	RL01-1380 to RL01-1280	RL01-1380	Storm Drain, Yard	City of Fort Smith to Arkansas River	Manhole	Grease	NEAH	94	752	Receiving Water (Riv, Str)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0074	fcf81c6c-a6a3-4ad5-9fbc-1cc9fc7e9e6	
AR0021750	03/23/2021	12:50 pm	03/23/2021	6:30 pm	03/24/2021	3617 Morris Dr	S007-0570 to S007-0550		Yard	N/A	Main Line	Line Break	NEAH	340	3,400	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,No Disinfection Performed	21-0082	7f50723d-953b-4ff8-8f69-3fb86d5d6689	
AR0021750	03/25/2021	8:45 am	03/26/2021	8:15 am	03/26/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	River, Stream, Creek	Massard Creek	Manhole	Rainfall	NEAH	1,410	352,500	Receiving Water (Riv, Str)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0086	481f13a0-29fc-49e9-8b89-8786d916fe34	
AR0021750	03/25/2021	6:33 pm	03/25/2021	8:00 pm	03/26/2021	1300 N 57th St	S002-1670 to S002-1660	S002-1670	Yard	N/A	Manhole	Grease	NEAH	87	1,740	Private PPTY (Ground)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0092	178a8268-2604-4523-8f5a-b74846b2bbf8	
10 TOTAL OVERFLOWS										360,608 TOTAL GALLONS SPILLED										