

Discharge Monitoring Report (DMR)

AR0021750 DMR SSOs May 2021

Print Date: 6/10/2021

Print Time: 7:26 am

Permit Number	Date SSO Started	Time SSO Started	Date SSO Stopped	Time SSO Stopped	Date SSO Reported	Location	Pipe Description	Manhole	Where SSO Went Into	Watershed	Type of SSO	Cause of SSO	Environmental Damage	Duration in Min.	Volume (Gallons)	Impact of SSO Incident	Steps Taken	Internal SSO ID	Web Confirmation Number
AR0021750																			
AR0021750	05/04/2021	9:00 am	05/05/2021	8:15 am	05/05/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	River, Stream, Creek	Massard Creek	Manhole	Rainfall	NEAH	1,395	348,750	Receiving Water (Riv, Str)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0147	f8248fe7-ad61-411f-a28d-8f46b6c88305
AR0021750	05/20/2021	8:35 am	05/23/2021	1:15 pm	05/21/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	Yard	Massard Creek	Manhole	Rainfall	NEAH	4,600	920,000	Receiving Water (Riv, Str)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0154	524194c9-8df3-46f1-8684-9df76e36f509
AR0021750	05/21/2021	5:00 pm	05/22/2021	3:00 pm	05/22/2021	8708 Meandering Way	M002-1700 to M002-0480	M002-1700	Yard	N/A	Manhole	Rainfall	NEAH	1,320	66,000	Private PPTY (Ground)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0163	bf11f1a3-a3de-4601-8b55-ce0da6a2b16
AR0021750	05/26/2021	10:05 am	05/26/2021	6:45 pm	05/27/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	River, Stream, Creek	Massard Creek	Manhole	Rainfall	NEAH	520	52,000	Receiving Water (Riv, Str)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0166	27aef4e8-840c-4c76-b461-6d430a97d895
AR0021750	05/27/2021	6:00 pm	05/27/2021	7:30 pm	05/28/2021	1321 N 52nd St	S006-2010 to S006-2000		Building	N/A	Service Line	Grease	NEAH	90	450	Basement Backup	Jet Clean,,Scheduled Cleanup,No Disinfection Performed	21-0167	2a8628bd-052b-4a3f-a666-97024f396352
AR0021750	05/28/2021	8:00 am	05/28/2021	1:30 pm	05/28/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	River, Stream, Creek	Massard Creek	Manhole	Rainfall	NEAH	330	66,000	Receiving Water (Riv, Str)	None Indicated,,Scheduled Cleanup,No Disinfection Performed	21-0170	8b50b3d1-c4c5-4c4e-b54b-b79199faf09d
AR0021750	05/27/2021	6:00 pm	05/27/2021	7:30 pm	05/28/2021	1321 N 52nd St	S006-2010 to S006-2000		Yard, Paved Area	City of Fort Smith to Arkansas River	Service Line	Grease	NEAH	90	450	Receiving Water (Riv, Str)	Jet Clean,,Scheduled Cleanup,Disinfection Performed	21-0171	e3e5a0a9-400f-4429-84e9-5cb266b2452a

7 TOTAL OVERFLOWS

1,453,650 TOTAL GALLONS SPILLED