

Discharge Monitoring Report (DMR)

AR0021750 DMR SSOs December 2020

Print Date: 1/12/2021

Print Time: 2:31 pm

| Permit Number | Date SSO Started | Time SSO Started | Date SSO Stopped | Time SSO Stopped | Date SSO Reported | Location | Pipe Description | Manhole | Where SSO Went Into | Watershed | Type of SSO | Cause of SSO | Environmental Damage | Duration in Min. | Volume (Gallons) | Impact of SSO Incident | Steps Taken | Internal SSO ID | Web Confirmation Number |
|------------------|------------------|------------------|------------------|------------------|-------------------|------------------------|------------------------|-----------|-------------------------------|---------------|--------------|--------------|----------------------|------------------|------------------|----------------------------|---|-----------------|--------------------------------------|
| AR0021750 | | | | | | | | | | | | | | | | | | | |
| AR0021750 | 12/01/2020 | 2:05 pm | 12/01/2020 | 3:14 pm | 12/02/2020 | 3801 N O St | S007-3350 to S007-T001 | | Paved Area | N/A | Main Line | Line Break | NEAH | 70 | 70 | Public Land (Ground) | Jet Clean,,Scheduled Cleanup,Disinfection Performed | 20-0322 | f73cfb47-96e4-483a-b38b-651e78889190 |
| AR0021750 | 12/05/2020 | 5:17 pm | 12/05/2020 | 5:53 pm | 12/06/2020 | 102 N 51st St | S006-1740 to S006-1730 | | Building | N/A | Service Line | Line Break | NEAH | 35 | 35 | Basement Backup | Repair,,No Cleanup Performed,No Disinfection Performed | 20-0327 | 78af30db-5ee3-4b40-a985-e0819edfc4d3 |
| AR0021750 | 12/07/2020 | 10:35 am | 12/07/2020 | 11:00 am | 12/08/2020 | 9201 Skypark Dr | SK01-0150 to SK01-0050 | SK01-0150 | Storm Drain, Yard, Paved Area | Massard Creek | Manhole | Roots | NEAH | 25 | 12,500 | Receiving Water (Riv, Str) | Jet Clean,Repair,Scheduled Cleanup,Disinfection Performed | 20-0332 | 2389d9cb-5e44-429c-a6de-b21c669c7186 |
| AR0021750 | 12/07/2020 | 10:35 am | 12/07/2020 | 11:00 am | 12/08/2020 | 9201 Skypark Dr | SK01-0150 to SK01-0050 | | Building | N/A | Service Line | Roots | NEAH | 25 | 12,500 | Basement Backup | Jet Clean,Repair,Scheduled Cleanup,Disinfection Performed | 20-0333 | 52ae6191-2b6b-4321-8818-d81d528d43bc |
| AR0021750 | 12/21/2020 | 8:45 am | 12/21/2020 | 11:00 am | 12/21/2020 | 10800 Hunters Point Rd | HP01-0050 to HP01-0020 | HP01-0050 | Yard | N/A | Manhole | Debris | NEAH | 135 | 135 | Private PPTY (Ground) | Jet Clean,,Scheduled Cleanup,Disinfection Performed | 20-0343 | 19715722-217b-4792-924e-6b57e0bf0b3d |

5 TOTAL OVERFLOWS

25,240 TOTAL GALLONS SPILLED