



June 21, 2013

Ms. Nancy Williams
EPA, Region 6
Compliance Assurance and Enforcement Division
1445 Ross Avenue
Dallas, TX 75202-2733

Re: AR0021750

Dear Ms. Williams:

The following violations were noted for the above referenced permit for May 2013.

Ammonia Nitrogen, 30 day average – 11.7 mg/l (Permit Limit – 5 mg/l)
Ammonia Nitrogen, 7 day average – Number Exceeding (4)
Ammonia Nitrogen, Loading average - 693 PPD (Permit Limit – 417 PPD)

No harmful effects were reported by the public or noted by utility personnel in the receiving stream.

Cool weather and above normal rainfall rates contributed to incoming wastewater temperatures averaging 21 degrees Celsius during May 2013, with several days below that mark. As a result, the organisms responsible for nitrification experienced slow growth and sufficient populations were not present to insure adequate nitrification. Wastewater temperatures have warmed during June and the facility is on course to meet permit limits for the current month.

Please direct questions to Mr. Steve Floyd at 479-784-2331 or email at sfloyd@fortsmithar.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Steve Parke".

Steve Parke
Director of Utilities

Pc: ADEQ, NPDES Section, Water Division
Steve Floyd, Superintendent-Water/Wastewater Operations

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358



June 21, 2013

Ms. Nancy Williams
EPA, Region 6
Compliance Assurance and Enforcement Division
Water Enforcement Branch (6EN-WC)
1445 Ross Avenue
Dallas, TX 75202-2733

RE: Overflow Reporting for NPDES Permit No.'s AR0033278 and AR0021750

Dear Ms. Williams:

Attached are the overflow reports for May 2013 for the above referenced permit numbers. It should be noted that in all instances the overflows were the result of a significant wet weather event. Overflow duration and flow are estimates only. No adverse impacts have been noted or reported to the City.

The City is currently developing revised SSO report forms for the P Street and Massard facilities. The new report form will include all SSO reporting parameters specified in the facility permit. The new reporting format should be available for use before the next reporting date.

Should you require further information, please advise.

Sincerely,

A handwritten signature in black ink, appearing to be "SP" or similar initials, written over a faint, illegible background.

Steve Parke
Director of Utilities

PC: ADEQ, NPDES Enforcement Division
Mr. Steven Floyd, Superintendent

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358

Wet Weather SSO's May 2013

<i>NPDES Permit</i>	<i>Date</i>	<i>Manhole</i>	<i>Description/Location</i>	<i>Estimated Hours</i>	<i>Estimated Gallons</i>
Massard - AR0021750	5/21/2013	M002-1390	S. 33rd & Vicksburg	38	200,000
Massard - AR0021750	5/21/2013	RL01-0140	#9 Riverlyn Ter	9	3,000
<i>Number of Events:</i>	2			<i>total</i>	203,000
P Street-AR0033278	5/21/2013	MC06-0305	1412 Phoenix Ave	22	6,000
P Street-AR0033278	5/21/2013	MC06-0542	1412 Phoenix Ave	24	18,000
P Street-AR0033278	5/21/2013	P005-3030	3200 N. M St.	20	64,000
P Street-AR0033278	5/21/2013	P007-0050	1425 N 34th St	8	9,000
P Street-AR0033278	5/21/2013	Z001-0460	5801 Boys Club Lane	20	82,000
P Street-AR0033278	5/21/2013	Z001-0770	5800 Boys Club Lane	20	64,000
<i>Number of Events:</i>	6			<i>total</i>	243,000

From: (479) 784-2330
Steve Floyd
City of Fort Smith
3900 Kelley Highway

Fort Smith, AR 72904

Origin ID: FSMA



J13111302120326

Ship Date: 24JUN13
ActWgt: 0.5 LB
CAD: 1731127/INET3370

Delivery Address Bar Code



SHIP TO: (501) 682-0638 **BILL SENDER**
NPDES Enforcement Section, Water
ADEQ
5301 Northshore Drive

North Little Rock, AR 72118



Ref #
Invoice #
PO #
Dept #

TUE - 25 JUN 3:00P
STANDARD OVERNIGHT

TRK# 7960 7605 8820
0201

72118
AR-US
LIT

X2 LITA



518G1/D777/93AB

After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.
Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.