



August 21, 2012

Ms. Nancy Williams  
EPA, Region 6  
Compliance Assurance and Enforcement Division  
1445 Ross Avenue  
Dallas, TX 75202-2733

Re: AR0021750

Dear Ms. Williams:

The following violations were noted for the above referenced permit for July 2012.

Ammonia Nitrogen, 7-day average (1)

No harmful effects were reported by the public or noted by utility personnel in the receiving stream.

As noted in previous correspondence, the Massard facility has experienced difficulty cultivating the necessary organisms responsible for nitrogen removal. The system has continued to improve with only one seven day average violation in July. The average thus far in August is 1.6 mg/l. We expect no further violations.

For additional information, please contact Mr. Steve Floyd at 479-784-2331.

Sincerely,

A handwritten signature in black ink, appearing to read "Steve Parke".

Steve Parke  
Director of Utilities

Pc: ADEQ, NPDES Section, Water Division  
Steve Floyd, Superintendent-Water/Wastewater Operations

**FEDEX**<sup>®</sup>  
press

Extremely Urgent

Page 1 of 1

From: (479) 784-2330  
Steve Floyd  
City of Fort Smith  
3900 Kelley Highway  
Fort Smith, AR 72904

Origin ID: FSMA

**FedEx**  
Express



J12201207160325

Ship Date: 21AUG12  
ActWgt: 0.5 LB  
CAD: 1731127/INET3300

Delivery Address Bar Code



SHIP TO: (501) 682-0638  
NPDES Enforcement Section, Water  
ADEQ  
5301 Northshore Drive

BILL SENDER

North Little Rock, AR 72118

Ref #  
Invoice #  
PO #  
Dept #

THU - 23 AUG A4  
\*\* 2DAY \*\*


TRK# 7987 9129 7320  
0201

72118  
AR-US  
MEM

**SH LITA**



515G20C34/AA44



container and  
conditions and  
ble FedEx  
FedEx Service

services,  
edex.com

Insert shipping  
document here.