

Monthly SSO Report October 2013

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0021750	between PL01-0180 & 0160	5400 Elm	Yard & building	60 minutes	grease	300 gallons	cleanout & basement	10/2/2013	4:10 PM	5:10 PM	Machine rodded
AR0033278	between S005-1510 & 0290	5422 Speaker	Yard	18 minutes	roots & grease	180 gallons	cleanout	10/10/2013	8:32 AM	9:00 AM	Machine rodded
AR0033278	between Z002-0140 & 0130	1600 Magnolia	Yard	155 minutes	roots, grease & debris	775 gallons	cleanout	10/10/2013	8:10 PM	10:45 PM	Hydro Cleaned
AR0033278	manhole FL01-1230	3423 Wilma	ditch	60 minutes	grease	300 gallons	manhole	10/16/2013	8:30 AM	9:30 AM	Hydro Cleaned
AR0033278	between FL01-2381 & 2380	3109 Willow	yard	60 minutes	debris	300 gallons	cleanout	10/16/2013	11:20 AM	12:20 PM	Hydro Cleaned
AR0033278	between W001-1180 & 1140	3002 Irving	yard	121 minutes	grease	121 gallons	cleanout	10/20/2013	12:39 PM	2:40 PM	Hydro Cleaned
AR0021750	manhole S007-3050	2008 No. 48 Cir.	yard & ditch	38 minutes	roots	190 gallons	manhole	10/23/2013	10:59 AM	11:37 AM	Machine rodded
AR0033278	between Z006-1270 & 1260	7900 Hermitage	yard	180 minutes	grease	900 gallons	cleanout	10/24/2013	12:30 AM	3:30 AM	Hydro Cleaned
AR0021750	between S003-0440 & 0400	108 No. 53	yard	90 minutes	grease	450 gallons	cleanout	10/26/2013	6:00 AM	8:30 AM	Machine rodded
AR0033278	between Z001-2470 & 2460	4818 So. 31	yard	180 minutes	roots	900 gallons	cleanout	10/27/2013	5:15 PM	8:15 PM	Hydro Cleaned
AR0021750	between M005-0080 & 0070	6738 Jackson	yard	56 minutes	roots	56 gallons	cleanout	10/31/2013	3:39 PM	4:25 PM	Machine rodded

CONFIRMATION NUMBER

76EFF63A-B7AD-4866-89EE-56F6881847F4

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 76EFF63A-B7AD-4866-89EE-56F6881847F4

Date Sent: 11/1/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**
 Date Overflow Began: **10/31/2013**
 Date Overflow Ended: **10/31/2013**

Facility name: **Massard**
 Time: **03:39 pm**
 Time: **04:25 pm**

Location: **6738 Jackson, between M005-0080 & 0070, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Volume: 56

(Give an estimate in gallons)

Impact of SSO Event: SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

FE23D175-8D4D-4D56-8D88-2245F3B40274

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: FE23D175-8D4D-4D56-8D88-2245F3B40274

Date Sent: 10/29/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name: **P Street**

Date Overflow Began: **10/27/2013**

Time: **05:15 pm**

Date Overflow Ended: **10/27/2013**

Time: **08:15 pm**

Location: **4818 So. 31, between manholes Z001-2470 & 2460, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Volume: 900

(Give an estimate in gallons)

Impact of SSO Event: SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded Disinfected and Deodorized
- Jet-Vac Hydro Cleaned
- Hand rodded Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah** Title **Superintendent** Telephone Number **(479) 784-2344**

Additional Comments if Needed: **SSO was not reported within 24 hours due to the employee's failure to turn in paperwork as previously instructed. Employee has been disciplined within accordance to city human resource procedure.**

CONFIRMATION NUMBER

417232AF-2B90-4F4C-A397-5B56B3F53441

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 417232AF-2B90-4F4C-A397-5B56B3F53441

Date Sent: 10/26/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name:

Massard

Date Overflow Began: **10/26/2013**

Time:

6:00 am

Date Overflow Ended: **10/26/2013**

Time:

8:30 am

Location: **108 No. 53, between manholes S003-0440 & 0400, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**
(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **450**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Affected Private Property (ground)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

0290B1C4-CFF4-4073-9338-526599138BE0

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 0290B1C4-CFF4-4073-9338-526599138BE0

Date Sent: 10/24/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name: **P Street**

Date Overflow Began: **10/24/2013**

Time: **12:30 am**

Date Overflow Ended: **10/24/2013**

Time: **3:30 am**

Location:

7900 Hermitage, between manholes Z006-1270 & 1260, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Volume:

900

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & J).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

FF0F3B83-9DFE-44F1-86C4-31B053917E51

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: FF0F3B83-9DFE-44F1-86C4-31B053917E51

Date Sent: 10/23/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name: **Massard**

Date Overflow Began: **10/23/2013**

Time: **10:59 am**

Date Overflow Ended: **10/23/2013**

Time: **11:37 am**

Location:

2088 No. 48 Cir., manhole number S007-3050, yard & ditch

200%

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: 190

(Give an estimate in gallons)

Impact of SSO Event: SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

86506E89-B6BC-4D9F-8C8B-C012F5EFFF29

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 86506E89-B6BC-4D9F-8C8B-C012F5EFFF29

Date Sent: 10/21/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **10/20/2013**

Time:

12:39 pm

Date Overflow Ended: **10/20/2013**

Time:

02:40 pm

Location: **3002 Irving, between manholes W001-1180 & 1140, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Volume:

121

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

0158F9BB-345E-4ADC-AAA4-46E25DF12C16

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 0158F9BB-345E-4ADC-AAA4-46E25DF12C16

Date Sent: 10/16/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **10/16/2013**

Time:

11:20 am

Date Overflow Ended: **10/16/2013**

Time:

12:20 pm

Location:

3109 Willow, between manholes FL01-2381 and 2380, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

300

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

9061C417-B598-46C4-B4E6-F2AD9B939B01

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 9061C417-B598-46C4-B4E6-F2AD9B939B01

Date Sent: 10/16/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**
 Date Overflow Began: **10/16/2013**
 Date Overflow Ended: **10/16/2013**
 Location: **3423 Wilma, manhole number FL01-1230, ditch**

Facility name:
 Time:
 Time:

P Street
08:30 am
09:30 am

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume:

300

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional
 Comments
 if Needed:

CONFIRMATION NUMBER

426F522F-C837-422D-AEA7-B4383C18375B

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 426F522F-C837-422D-AEA7-B4383C18375B

Date Sent: 10/11/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **10/10/2013**

Time:

08:10 pm

Date Overflow Ended: **10/10/2013**

Time:

10:45 pm

Location:

1600 Magnolia, between manholes 2002-0140 & 0130, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

775

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments: **clean up and deodorization is being scheduled**

if Needed:

CONFIRMATION NUMBER

6799317A-C248-4F78-AB2F-CCB6489BE773

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 6799317A-C248-4F78-AB2F-CCB6489BE773

Date Sent: 10/10/2013

SSO Bypass Upset

Facility Permit Number:	AR0033278	Facility name:	P Street WWTP
Date Overflow Began:	10/10/2013	Time:	08:32 am
Date Overflow Ended:	10/10/2013	Time:	09:00 am
Location:	5422 Speaker (clean out)		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm)

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Clean Out**

(Enter overflow type if not listed)

Volume: **180**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Affected Private Property (ground)**

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded Disinfected and Deodorized
- Jet-Vac Hydro Cleaned
- Hand rodded Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Superintendent** Telephone Number **(479) 784-2330**

Additional Comments if Needed: **Clean up scheduled. Odo-Ban disinfectant applied to the area.**

CONFIRMATION NUMBER

C7703CBB-7134-4BB6-B3D8-21667D9F08AA

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: C7703CBB-7134-4BB6-B3D8-21667D9F08AA

Date Sent: 10/3/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name: **Massard**

04:10 pm

Date Overflow Began: **10/02/2013**

Time:

05:10 pm

Date Overflow Ended: **10/02/2013**

Time:

Location:

5400 Elm, between Manholes PL01-0180 & 0160, yard and building basement

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Building**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

300 gallons

(Give an estimate in gallons)

Impact of SSO Event:

Basement Backup

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & J).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

From: (479) 784-2330
 Steve Floyd
 City of Fort Smith
 3900 Kelley Highway
 Fort Smith, AR 72904

Origin ID: FSMA



J13201306280326

Ship Date: 20NOV13
 ActWgt: 0.5 LB
 CAD: 1731127/INET3430

Delivery Address Bar Code



Ref #
 Invoice #
 PO #
 Dept #

SHIP TO: (501) 682-0638 **BILL SENDER**
NPDES Enforcement Section, Water
ADEQ
5301 Northshore Drive



North Little Rock, AR 72118

FRI - 22 NOV AA
**** 2DAY ****

TRK# 7972 0661 6685
 0201

SA LITA

72118
 AR-US
 LIT



51AG1/05E6/1A9E

After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number. Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.