



June 11, 2013

Ms. Nancy Williams
U.S. Environmental Protection Agency, Region VI
Compliance Assurance and Enforcement Branch
Water Enforcement Branch (6EN-WC)
1445 Ross Avenue
Dallas, Texas 75202-2733

RE: Collection System Overflow - NPDES Permit No. AR0021750

Dear Ms. Williams:

In compliance with NPDES permit requirements, the following information is submitted concerning a collection system overflow.

Location of Overflow	Overflow Volume Est.	Date	Action Taken
8819 Rogers Ave. MH No. M004-0020	15,000 gallons	05/30/13	Emergency Repair

The overflow event listed above was the result of a mainline failure. The pipeline was washed out in a storm drainage ditch. The overflow was stopped by making an emergency repair.

Should you have questions regarding this event, please do not hesitate to call.


Sincerely,

A handwritten signature in black ink, appearing to read "Steve Parke".

Steve Parke
Director of Utilities

pc: Arkansas Department of Environmental Quality, NPDES Enforcement Section ✓
Leroy Jeremiah, Line Maintenance Superintendent
Jimmie Johnson, Project Engineer
Darren Bonds, Supervisor
Mitchell Vinsant, Supervisor

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358



3900 Kelley Hwy.
Fort Smith, Arkansas 72904



Arkansas Department of Environmental Quality
NPDES Section
5301 Northshore Drive
North Little Rock, AR 72118-5317

neopost[®]

06/12/2013

US POSTAGE



FIRST-CLASS MAIL

\$00.46⁰

ZIP 72904
041L10214410