



April 24, 2013

Ms. Nancy Williams
U.S. Environmental Protection Agency, Region VI
Compliance Assurance and Enforcement Branch
Water Enforcement Branch (6EN-WC)
1445 Ross Avenue
Dallas, Texas 75202-2733

RE: Collection System Overflow - NPDES Permit No. AR0021750

Dear Ms. Williams:


In compliance with NPDES permit requirements, the following information is submitted concerning a collection system overflow.

Location of Overflow	Overflow Volume Est.	Date	Action Taken
So. 58 & Gary MH No. M007-1625	500 gallons	04/22/13	Power Rodded

The overflow event listed above was the result of a mainline stoppage caused by rags. The overflow was stopped when the rags were removed by power rodding. The area was cleaned and disinfected with OdorBan.

Should you have questions regarding this event, please do not hesitate to call.

Sincerely,


Steve Parke
Director of Utilities

pc: Arkansas Department of Environmental Quality, NPDES Enforcement Section ✓
Leroy Jeremiah, Line Maintenance Superintendent
Jimmie Johnson, Project Engineer
Darren Bonds, Supervisor
Mitchell Vinsant, Supervisor

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358



3900 Kelley Hwy.
Fort Smith, Arkansas 72904

neopost[®]
04/24/2013
US POSTAGE

FIRST-CLASS MAIL

\$00.46⁰



ZIP 72904
041L10214410



Arkansas Department of Environmental Quality
NPDES Section
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118531799

