



POST
FEB 19 2013
MARKED

February 15, 2013

Ms. Nancy Williams
EPA, Region 6
Compliance Assurance and Enforcement Division
Water Enforcement Branch (6EN-WC)
1445 Ross Avenue
Dallas, TX 75202-2733

RE: Overflow Reporting for NPDES Permit No.'s AR0033278 and AR0021750

Dear Ms. Williams:

Attached are the overflow reports for January 2013 for the above referenced permit numbers. It should be noted that in all instances the overflows were the result of a significant wet weather event. Overflow duration and flow are estimates only. No adverse impacts have been noted or reported to the City.

Should you require further information, please advise.

Sincerely,

A handwritten signature in black ink, appearing to be "Steve Parke".

Steve Parke
Director of Utilities

PC: ADEQ, NPDES Enforcement Division
Mr. Steven Floyd, Superintendent

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358

Wet Weather SSO's January 2013

POST
FEB 19 2013
MARKED

<i>NPDES Permit</i>	<i>Date</i>	<i>Manhole</i>	<i>Description/Location</i>	<i>Estimated Hours</i>	<i>Estimated Gallons</i>
Massard - AR0021750	1/29/2013	M002-1390	S. 33rd & Vicksburg	12	2,800
Massard - AR0021750	1/29/2013	RL01-0110	#5 Riverlyn Ter	13	14,000
Massard - AR0021750	1/29/2013	RL01-0140	#9 Riverlyn Ter	13	39,000
Massard - AR0021750	1/29/2013	RL01-0680	Carol Ann Cross Park	6	400
<i>Number of Events:</i>	4			<i>total</i>	56,200
P Street-AR0033278	1/29/2013	MC06-0305	1412 Phoenix Ave	12	25,000
<i>Number of Events:</i>	1			<i>total</i>	25,000