

Monthly SSO Report August 2013

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0021750	Between M005-1060 & 1050	9505 Bellhaven View	Yard	122 minutes	roots	122 gallons	service line cleanout	8/2/2013	6:29 PM	8:14 PM	Machine Rodded
AR0033278	MC05-2240	2408 Houston	Yard	185 minutes	roots & debris	925 gallons	manhole	8/3/2013	1:52 PM	3:37 PM	Machine Rodded
AR0021750	Between M004-0140 & 0130	2901 Massard	Yard	70 minutes	grease	1450 gallons	service line cleanout	8/6/2013	8:00 AM	9:10 AM	Hydro Cleaned
AR0033278	Between P010-1240 & 1230	301 No. 18	Rear Yard	225 minutes	damaged	225 gallons	service line cleanout	8/8/2013	12:58 PM	4:55 PM	Repaired Service Line
AR0033278	Z006-1810	1317 Meadow Dr.	Yard	90 minutes	roots	450 gallons	manhole	8/13/2013	1:30 PM	3:00 PM	Hydro Cleaned
AR0033278	Z004-1630	10003 Inverness	Storm sewer	45 minutes	roots & grease	1125 gallons	manhole	8/16/2013	1:50 PM	2:35 PM	Machine Rodded
AR0021750	RL01-0220	27 Riverlyn Drive	Yard	120 minutes	roots	600 gallons	manhole	8/16/2013	6:05 PM	8:05 PM	Hydro Cleaned
AR0021750	S008-1290	2100 No. 31	Paved area	83 minutes	grease	830 gallons	manhole	8/24/2013	7:57 PM	9:27 PM	Machine Rodded
AR0033278	Between MC05-1130 & 1120	3220 So. 16	Yard	101 minutes	grease	505 gallons	building	8/25/2013	10:34 AM	12:15 PM	Machine Rodded
AR0033278	Between Z004-1320 & 1310	3101 Glen Flora Way	Yard	810 minutes	line failure & debris	810 gallons	service line cleanout	08/25/2013 & 08/26/2013	8:30 PM	10:00 AM	Line Repair
AR0033278	Between CS01-0700 & 0690	6908 So. 9	Yard	85 minutes	roots	85 gallons	service line cleanout	8/28/2013	5:55 PM	7:20 PM	Machine Rodded
AR0021750	Between S006-1160 & 1130	4323 Kinkead	Garage Floor & Yard	27 minutes	grease	135 gallons	floor drain	8/29/2013	12:58 PM	1:25 PM	Machine Rodded

CONFIRMATION NUMBER

E434E521-7D1B-4000-914C-0F14CA7B1A53

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: E434E521-7D1B-4000-914C-0F14CA7B1A53

Date Sent: 8/30/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name:

Massard

Date Overflow Began: **08/29/2013**

Time:

12:58 pm

Date Overflow Ended: **08/29/2013**

Time:

01:25 pm

Location:

4323 Kinkead, between Manholes S006-1160 & 1130, garage floor and yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **garage floor drain**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

135 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

Owner will be notified of Ord. 68-12, damage claim policy

CONFIRMATION NUMBER

F9784FA5-792D-4EC8-BCA9-08A643857B4E

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: F9784FA5-792D-4EC8-BCA9-08A643857B4E

Date Sent: 8/29/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **08/28/2013**

Time:

05:55 pm

Date Overflow Ended: **08/28/2013**

Time:

07:20 pm

Location:

6908 So. 9, between Manholes CS01-0700 & 0690, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

85 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

2C0B544D-32F3-40A8-B017-5448B66E206A

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 2C0B544D-32F3-40A8-B017-5448B66E206A

Date Sent: 8/26/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **08/25/2013**

Time:

08:30 pm

Date Overflow Ended: **08/26/2013**

Time:

10:00 am

Location:

3101 Glen Flora Way, between manholes Z004-1320 & 1310, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: 810 gallons

(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Emergency Repair

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed: Original hydro cleaning effort failed to totally stop overflow on Sunday evening. Construction crew returned to site Monday morning and made emergency excavation/repair.

CONFIRMATION NUMBER

7AFAA65E-CB30-4C47-ACFB-980C87AED225

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 7AFAA65E-CB30-4C47-ACFB-980C87AED225

Date Sent: 8/26/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **08/25/2013**

Time:

10:34 am

Date Overflow Ended: **08/25/2013**

Time:

12:15 pm

Location:

3220 So. 16, between Manhole MC05-1130 & 1120, under building

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume:

505 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

B0FF87DF-B315-41F4-8FAE-BAFB5199A3E7

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: B0FF87DF-B315-41F4-8FAE-BAFB5199A3E7

Date Sent: 8/25/2013

SSO Bypass Upset

Facility Permit Number: AR0021750
Date Overflow Began: 08/24/2013
Date Overflow Ended: 08/24/2013

Facility name: Massard
Time: 07:57 pm
Time: 09:27 pm

Location: 2100 No. 31, Manhole number S008-1290, paved area

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: 830 gallons
(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By Leroy Jeremiah

Title Water & Wastewater Line Maintenance Supt.

Telephone Number (479) 784-2344

Additional Comments if Needed:

CONFIRMATION NUMBER

65F21794-B149-4B6D-BE10-511CD5A02D07

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 65F21794-B149-4B6D-BE10-511CD5A02D07

Date Sent: 8/17/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name:

Massard

Date Overflow Began: **08/16/2013**

Time:

06:05 pm

Date Overflow Ended: **08/16/2013**

Time:

08:05 pm

Location:

27 Riverlyn Drive, Manhole number RL01-0220, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume:

600 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

disinfection and deodorization is scheduled for Monday 08/19/2013

CONFIRMATION NUMBER

B2948532-A773-479A-8344-2CD0B7C75B2A

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: B2948532-A773-479A-8344-2CD0B7C75B2A
Date Sent: 8/16/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**
 Date Overflow Began: **08/16/2013**
 Date Overflow Ended: **08/16/2013**
 Location: **10003 Inverness, manhole number 2004-1630, storm sewer**

Facility name:
 Time:
 Time:

P Street
01:50 pm
02:35 pm

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: **1125 gallons**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah** Title **Water & Wastewater Line Maintenance Supt.** Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

E88AE89A-A568-45B2-9196-03647367CCFA

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: E88AE89A-A568-45B2-9196-03647367CCFA
Date Sent: 8/13/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**
 Date Overflow Began: **08/13/2013**
 Date Overflow Ended: **08/13/2013**
 Location: **1317 Meadow Dr., manhole Z006-1810**

Facility name:
 Time:
 Time:

P Street
01:30 pm
03:00 pm

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

450 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Receiving Water (river,stream)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional
 Comments
 if Needed:

CONFIRMATION NUMBER

5A0518E2-4C7C-436F-8172-C85B98EA4C40

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 5A0518E2-4C7C-436F-8172-C85B98EA4C40
Date Sent: 8/9/2013

SSO Bypass Upset

Facility Permit Number: AR0033278
Date Overflow Began: 08/08/2013
Date Overflow Ended: 08/08/2013
Location:

Facility name:
Time:
Time:

P Street
12:58 pm
04:55 pm

301 No. 18, between manholes P010-1240 and 1230, rear yard and easement

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: 225 gallons

(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Receiving Water (river,stream)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

repaired

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By Leroy Jeremiah **Title** Water & Wastewater Line Maintenance Supt.

Telephone Number (479) 784-2344

Additional Comments if Needed: Arkansas Oklahoma Gas Co. bored through a sanitary sewer service line

CONFIRMATION NUMBER

7CA44CB3-210F-43FB-A5BD-862354FFE602

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 7CA44CB3-210F-43FB-A5BD-862354FFE602
Date Sent: 8/6/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**
 Date Overflow Began: **08/06/2013**
 Date Overflow Ended: **08/06/2013**
 Location: **2901 Massard, between manholes M004-0140 & 0130, yard**

Facility name: **Massard**
 Time: **08:00 am**
 Time: **09:10 am**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: **1450 gallons**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah** Title **Water & Wastewater Line Maintenance Supt.** Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

52DBB230-DC75-43B5-8EEB-5630EF0E8FF9

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 52DBB230-DC75-43B5-8EEB-5630EF0E8FF9

Date Sent: 8/4/2013

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street

Date Overflow Began: **08/03/2013**

Time:

01:52 pm

Date Overflow Ended: **08/03/2013**

Time:

03:37 pm

Location:

2408 Houston, Manhole MC05-2240, yard

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

925 gallons

(Give an estimate in gallons)

Impact of SSO Event:

SSO Reached Receiving Water (river,stream)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

CONFIRMATION NUMBER

71344012-6836-4D58-8C06-FA9BDBEDC9A1

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 71344012-6836-4D58-8C06-FA9BDBEDC9A1

Date Sent: 8/3/2013

SSO Bypass Upset

Facility Permit Number: **AR0021750**

Facility name: **Massard**

06:26 pm

Date Overflow Began: **08/02/2013**

Time:

08:14 pm

Date Overflow Ended: **08/02/2013**

Time:

Location: **9505 Bellhaven View, between manhole M005-1060 and 1050, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **122 gallons**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage


- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Water & Wastewater Line Maintenance Supt.**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:



From: (479) 784-2330
Steve Floyd
City of Fort Smith
3900 Kelley Highway

Fort Smith, AR 72904

Origin ID: FSMA



J13201306280326

Ship Date: 23SEP13
ActWgt: 0.5 LB
CAD: 1731127/INET3430

Delivery Address Bar Code



Ref #
Invoice #
PO #
Dept #

SHIP TO: (501) 682-0638 **BILL SENDER**
NPDES Enforcement Section, Water
ADEQ
5301 Northshore Drive

North Little Rock, AR 72118

WED - 25 SEP AA
**** 2DAY ****


TRK# 7967 4688 2340
0201

72118
AR-US
LIT

SA LITA



51AG182561A9E



After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

FSMA 71