



September 19, 2012

Ms. Nancy Williams
U.S. Environmental Protection Agency, Region VI
Compliance Assurance and Enforcement Branch
Water Enforcement Branch (6EN-WC)
1445 Ross Avenue
Dallas, Texas 75202-2733

RE: Collection System Overflow - NPDES Permit No. AR0021750

Dear Ms. Williams:

In compliance with NPDES permit requirements, the following information is submitted concerning a collection system overflow.

Location of Overflow	Overflow Volume Est.	Date	Action Taken
4120 Rogers Ave. MH No. S003-1320	1000 gallons	09/18/12	Power Rodded

The overflow event listed above was the result of a mainline stoppage caused by grease. The overflow was stopped when the mainline was power rodded.

Should you have questions regarding this event, please do not hesitate to call.

Sincerely,

Steve Parke
Director of Utilities

pc: Arkansas Department of Environmental Quality, NPDES Enforcement Section ✓
Leroy Jeremiah, Line Maintenance Superintendent
Jimmie Johnson, Project Engineer
Darren Bonds, Supervisor
Mitchell Vinsant, Supervisor

Utility Department • 3900 Kelley Hwy.
Fort Smith, Arkansas 72904
(479) 784-2231 • FAX (479) 784-2358



3900 Kelley Hwy.
Fort Smith, Arkansas 72904

neopost[®]
10/01/2012
US POSTAGE

FIRST-CLASS MAIL

\$00.45⁰⁰



ZIP 72904
041L10214410



Arkansas Department of Environmental Quality
NPDES Section
5301 Northshore Drive
North Little Rock, AR 72118-5317