



P. 479-968-2105

F. 479-968-3265

"Award Winning Water"

May 10, 2018

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for April 2018 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Total Suspended Solids (TSS) – Mass, Monthly Avg.
2. Total Suspended Solids (TSS) – Monthly Avg.
3. Total Suspended Solids (TSS) – 7-day Avg.
4. Ammonia Nitrogen (NH₃-N) – Mass Monthly Avg
5. Ammonia Nitrogen (NH₃-N) – Monthly Avg.
6. Ammonia Nitrogen (NH₃-N) – 7-day Avg
7. Fecal Coliform Bacteria (FCB) – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations were a result of the treatment plants continued inability to oxidize the ammonia thereby the nature of the sludge is poor settling and subject to wash out during increased flows at the plant. City Corporation continues to investigate cause of reduced biological activity.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com