



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105

Fax (479) 968-3265

September 9, 2015

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for August, 2015, as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Chlorine, total residual – Inst. Max
2. Oxygen, Dissolved – Inst. Min.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The chlorine violation was caused by a faulty chlorine analyzer used to control the sulfur dioxide feed. The meter showed no chlorine residual and had shut off the sulfur dioxide. The system has been placed in manual mode and operators monitor feed rates each day to ensure proper operation
2. The Dissolved Oxygen (DO) violation occurred during a period of heavy rain event, during this time the flow at the effluent was elevated with minimal fall over the contact weirs and effluent weir allowing for this violation. DO was checked again later in the day after flow returned to normal and the DO was within permit limits.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext. 222.

Sincerely,



Steve Mallett
General Manager

cc: Larry Collins
Randy Bradley
File