



P. 479-968-2105

F. 479-968-3265

"Award Winning Water"

September 6, 2017

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for August 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Dissolved Oxygen (DO) - Inst. Min.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The DO violation occurred on August 30, 2017 and was caused by a slug pollutant at the treatment plant. The slug caused the oxygen demand in our activated sludge process to exceed our limitation and effected the processes ability to reduce ammonia as well as the DO requirement. Pretreatment staff is currently working with all permitted industries in efforts to determine source of the slug. Samples of the slug where delivered to our contract lab for extensive testing in our efforts to determine the composition. The plant has recovered and as of the date of the letter the effluent is in compliance with permit limits.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com