



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

September 11, 2018

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for August 2018 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Chlorine, total residual (TRC) – Inst.Max.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The TRC violation occurred on Friday August 24, 2019. On this date the treatment plant was experiencing a toxic/inhibition. The chlorine feed was lowered, and sulfur dioxide was increased in an effort to ensure the TRC was in compliance with permit limit but these efforts failed to completely remove the chlorine from our effluent. During the day the plant responded well and by late afternoon all permit parameters were compliant with permit limits.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in blue ink, appearing to read "Steve Mallett", is written over a white background.

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com