



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

January 9, 2018

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for December 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Chlorine, Total Residual – Inst. Max.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The TRC violation was a result of a new operator that allowed the sulfur dioxide system to be adjusted below a level adequate to remove the residual chlorine in the effluent. Operator has been instructed again of proper adjustment to the sulfur dioxide system and is being checked by our senior operator.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com