

March 18, 2011

Craig Noble, General Manager City Corporation Russellville Water and Sewer System P.O. Box 3186 Russellville, AR 72811

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Noble:

A review of the NPDES file for the City of Russellville for the period of June 1, 2010 thru January 31, 2011 reveals the following compliance issue:

The facility reported 8 violation of Part I, Section A. of NPDES Permit No.: AR0021768. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
06/30/2010	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	15.6	15.1
07/31/2010	001A	Copper, total recoverable (MO AVG, µg/L	10.42	9.24
07/31/2010	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	15.7	15.1
10/31/2010	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	18.2	15.1
10/31/2010	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	21	20.4
12/31/2010	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	18.7	15.1
01/31/2011	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	17.3	15.1
01/31/2011	001A	Nitrogen, nitrate total (as NO3) (MO AVG, mg/L)	21.7	20.4

The Department expects the City of Russellville to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,

alan anders

Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch