

ADEQ

ARKANSAS
Department of Environmental Quality

June 21, 2011

Craig Noble, Wastewater Superintendent
City Corporation
Russellville Water and Sewer
P.O. Box 3186
Russellville, AR 72811

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Noble:

A review of the NPDES file for City Corporation- Russellville Water and Sewer for the period of April 1, 2011 thru April 30, 2011 reveals the following compliance issue:

The facility reported 2 violations of Part I, Section A. of NPDES Permit No.: AR0021768. The effluent violations reported on the DMR are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
04/30/2011	001A	Solids, total suspended (MO AVG, lb/d)	1219.5	1217.6
04/30/2011	001A	Coliform, fecal general (7 DA GEO, #/100mL)	18197	2000

The Department assumes that City Corporation, Russellville Water and Sewer continues to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

