

June 12, 2020

Steve Mallett, General Manager  
City Corporation  
P.O. Box 3186  
Russellville, AR 72811

email: [rbradley@citycorporation.com](mailto:rbradley@citycorporation.com)

RE: NPDES Permit Number AR0021768, AFIN 58-00105  
Permitted Effluent Limitation Violations

Dear Mr. Dobler,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 17 violations of Part I, Section A of NPDES Permit No. AR0021768 during the review period. DEQ requires the CITY CORP WWTP to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,



Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
04/30/2020	001-A	Solids, total suspended, MO AVG, lb/d	1217.6	1655	36%	E90
04/30/2020	001-A	Solids, total suspended, MO AVG, mg/L	20	21.8	9%	E90
04/30/2020	001-A	Solids, total suspended, 7 DA AVG, mg/L	30	34.6	15%	E90
04/30/2020	001-A	BOD, carbonaceous [5 day, 20 C], MO AVG, lb/d	913.2	1060.6	16%	E90
04/30/2020	001-A	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	22.5	24.1	7%	E90
02/29/2020	001-A	Solids, total suspended, MO AVG, lb/d	1217.6	4207.5	246%	E90
02/29/2020	001-A	Solids, total suspended, MO AVG, mg/L	20	53.2	166%	E90
02/29/2020	001-A	Solids, total suspended, 7 DA AVG, mg/L	30	71.2	137%	E90
02/29/2020	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	243.5	392.5	61%	E90
02/29/2020	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	4	5	25%	E90
02/29/2020	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	6	7.2	20%	E90
02/29/2020	001-A	Copper, total recoverable, MO AVG, lb/d	0.45	0.52	16%	E90
02/29/2020	001-A	Coliform, fecal general, 30DA GEO, #/100mL	1000	1029	3%	E90
02/29/2020	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	2280	14%	E90
02/29/2020	001-A	BOD, carbonaceous [5 day, 20 C], MO AVG, lb/d	913.2	1775.9	94%	E90
02/29/2020	001-A	BOD, carbonaceous [5 day, 20 C], MO AVG, mg/L	15	22.5	50%	E90
02/29/2020	001-A	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	22.5	28.3	26%	E90