



P. 479-968-2105

F. 479-968-3265

"Award Winning Water"

March 14, 2018

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for February 2018 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Dissolved Oxygen (DO) – Inst. Min.
2. pH – Minimum
3. Total Suspended Solids (TSS) – Mass, Monthly Avg.
4. Total Suspended Solids (TSS) – Monthly Avg.
5. Total Suspended Solids (TSS) – 7-day Avg.
6. Ammonia Nitrogen (NH₃-N) – Mass Monthly Avg
7. Ammonia Nitrogen (NH₃-N) – Monthly Avg.
8. Ammonia Nitrogen (NH₃-N) – 7-day Avg.
9. Total Residual Chlorine (TRC) – Inst. Max.
10. Fecal Coliform Bacteria (FCB) – 7-day Avg.
11. BOD Carbonaceous (CBOD) – Mass Monthly Avg.
12. BOD Carbonaceous (CBOD) – Monthly Avg.
13. BOD Carbonaceous (CBOD) – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations were a result of the drastic increase in flows to the plant due to local flooding during this reporting period. City Corporation continues efforts to reduce I&I within our collection system and we will continue to make improvements to reduce the effects of this type on our treatment plant.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com