



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

February 8, 2018

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for January 2018 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia total (as N) – 7 Day Avg.
2. Coliform, Fecal – 7 Day Geo. Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations were a result of a two difference events at the treatment plant during January. The ammonia violation occurred during the 4th week of the month. We experienced two days with above permit limit ammonia in our effluent; the ammonia issue corrected itself and is currently within permit limits.
2. The Fecal Coliform violation was caused by an issue with our chlorine feed system. The system failed and it took our staff two days to correct the issue. Once we were about to feed correct amount of chlorine the Fecal count was within permit limits.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,


Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com