



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

August 8, 2017

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for July 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended (TSS) – 7-day Avg. Conc.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The cause for this violation was high flows due to local heavy rainfall and some light sludge in the final clarifiers during the first week of this reporting period. This issue has been corrected and as of the date of this notice the facility is compliant with all permit limits.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com