



205 W 3rd Place P.O. Box 3186
Russellville, AR 72811-3186
Office (479) 968-2105
Fax (479) 968 3265

July 7, 2016

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for June 2016 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – 7-day Avg.
2. Coliform, Fecal – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The TSS violation occurred on June 14, 2016. On this date the WW Operations Manager instructed the operators to take one of the final clarifiers off line due to a pumping issue. When this clarifier was taken off line one of the remaining two clarifiers began to wash out and caused the increase in TSS. The clarifier was put back on line and the issue was corrected within a couple hours. The fecal coliform violation occurred during the first week of this reporting period and was a result of a chlorine feed line that was stopped up. The operators corrected the issue and the plant is currently in compliance with fecal coliform parameter.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in black ink, appearing to read "Steve Mallett", is written over a faint, larger version of the same signature.

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File