



P. 479-968-2105

F. 479-968-3265

*"Award Winning Water"*

June 12, 2018

Mr. Alan Anderson  
Enforcement Analyst  
Water Division/Enforcement Branch  
Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for May 2018 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Total Suspended Solids (TSS) – Mass, Monthly Avg.
2. Total Suspended Solids (TSS) – Monthly Avg.
3. Total Suspended Solids (TSS) – 7-day Avg.
4. Dissolved Oxygen (DO) – Inst. Min.
5. pH- Inst Min.
6. Fecal Coliform Bacteria (FCB) – 7-day Avg.
7. BOD, carbonaceous (CBOD) – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations were a result of the treatment plants continued inability to oxidize the ammonia thereby the nature of the sludge is poor settling and subject to wash out during increased flows at the plant. These permit violations occurred mostly during the first part of the month, City Corporation has made some operational changes suggested by an environmental scientist. These operational changes have made improvements and the plant is currently meeting all permit limits.

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com



P. 479-968-2105

F. 479-968-3265

*"Award Winning Water"*

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett  
Chief Executive Officer

cc: Larry Collins  
Randy Bradley  
File

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com