



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

May 15, 2020

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for April 2020 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – 7-Day Avg.
4. BOD, Carbonaceous – Mon. Avg. Loading
5. BOD, Carbonaceous – 7-Day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations are a result of excessive loss of solids from our final clarifiers due to excess flows caused by local heavy rainfall throughout the month of April. The plant recorded a total rainfall of 6.15 inches for the month. During these events, the flow through the plant, at times, was recorded to be >14 MGD.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com