



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

May 13, 2019

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for April 2019 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – 7-Day Avg
4. Nitrogen, Ammonia – Mon. Avg. Loading
5. Nitrogen, Ammonia – Mon. Avg. Con.
6. Nitrogen, Ammonia – 7-Day Avg.
7. Fecal Coliform Bacteria (FCB) – Mon. Avg.
8. Fecal Coliform Bacteria (FCB) – 7-day Avg.
9. Oxygen, Dissolved – Inst. Minimum
10. BOD, carbonaceous, 5-day – Mon. Avg. Loading

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations are a result of the excessive loss of solids from our final clarifiers due to excess flows caused by local heavy rainfall on April 17 - 18, 2019. During this event the flow through the plant was recorded to be >18 MGD and even though the depth of sludge in our final basins were within proper operational levels it washed large amounts of solids out into the effluent. The plant recovered well over the weekend and all parameters were within permit limits on Monday April 22, 2019.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com