



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

May 13, 2021

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for April 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total – Mon. Avg. Loading
2. Nitrogen, Ammonia Total – Mon. Avg. Con.
3. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- The above ammonia violations are related to increased flows from local rain events, slug loading that inhibited the denitrification process in our aeration basins and led to our secondary clarifiers washing out due to poor settling sludge blankets.

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Manager at 479-968-2080 ext. 224.

Sincerely,

A handwritten signature in blue ink, appearing to read "S. Mallett", is written over a white background.

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com