



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

September 20, 2022

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for August 2022 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Oxygen, dissolved (DO) – Inst. Min.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Due to construction improvements, the installation of the new PAA basin effluent weir caused hydraulic changes, which in turn made the PCW outfall weir become submerged. This event directly affected the dissolved oxygen (DO) in the effluent. The PCW is back in compliance since this event.

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,


Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com