



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105
Fax (479) 968-3265

February 12, 2015

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for January 2015 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Oxygen, Dissolver – Inst. Min.
2. Total Suspended Solids (TSS) – Monthly Avg. Mass (lbs/day)
3. Total Suspended Solids (TSS) – Monthly Avg. Concentration
4. Total Suspended Solids (TSS) – 7-day Avg.
5. Nitrogen, Ammonia – Monthly Avg. Mass (lbs/day)
6. Nitrogen, Ammonia – Monthly Avg. Concentration
7. Nitrogen, Ammonia – 7-day Avg.
8. Fecal Coliform Bacteria – 30-Day Avg.
9. Fecal Coliform Bacteria – 7-day Avg.
10. CBOD5 – Monthly Avg. Mass (lbs/day)
11. CBOD5 – Monthly Avg. Concentration
12. CBOD5 – 7-Day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. All the above violations are a direct result of the construction currently in progress at the wastewater plant. The new process has shown that it produces more sludge than our

current operations have the ability to process. This increase in sludge production and temporary break down of the sludge press allowed for sludge inventory in the clarifiers and basins to increase above the operational levels. City Corporation is currently working with several contract engineering firms to address this issue and will have a corrective action plan.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext 222.

Sincerely,

A handwritten signature in blue ink, appearing to read "S. Mallett", written in a cursive style.

Steve Mallett
General Manager

cc: Larry Collins
Randy Bradley
File