



P. 479-968-2105  
F. 479-968-3265

*"Award Winning Water"*

February 22, 2021

Ms. Christina Brown  
Enforcement Analyst  
Water Division/Enforcement Branch  
Division of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for January 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Max. 7-Day Avg. Con.
2. Nitrogen, Ammonia Total – Mon. Avg. Con.
3. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.
4. Coliform, Fecal – Max. 7-Day Geo.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- The above TSS violation is an effect of slug loading that came through the PCW. The ammonia violations are a result of an increase in plant loading which directly affected the denitrification process in our aeration basins. The fecal coliform violation is related to the increase in TSS and demand. The PCW also experience a couple of slugs towards the end of the month that affected our denitrification process as well.

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com



P. 479-968-2105  
F. 479-968-3265

***"Award Winning Water"***

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Manager at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett  
Chief Executive Officer  
City Corporation