



P. 479-968-2105  
F. 479-968-3265

*"Award Winning Water"*

August 12, 2019

Mr. Alan Anderson  
Enforcement Analyst  
Water Division/Enforcement Branch  
Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for July 2019 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia – Mon. Avg. Con.
2. Nitrogen, Ammonia – 7-day Avg.
3. Total Recoverable Zinc – Mon. Avg. Loading
4. Total Recoverable Zinc – Mon. Avg. Con.
5. Total Recoverable Zinc – Mon. Av
6. Total Residual Chlorine – Inst. Max.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above Ammonia violations occurred due to an automatic valve malfunction connected to the inlet side of an aeration basin turbine. After discovering the malfunction, the PCW staff corrected the issue, the oxygen levels climbed, and the plant was back in compliance within three days.
2. The above Zinc violations are being investigated by our Pretreatment Coordinator for possible causes.
3. The above TRC violation happened after putting a secondary clarifier back into service which in turn sent a slug of chlorine through our final effluent. The plant was back in compliance within the hour of the event.

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com



P. 479-968-2105  
F. 479-968-3265

***"Award Winning Water"***

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett  
Chief Executive Officer

cc: Larry Collins  
Randy Bradley  
File

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com