



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

August 18, 2020

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for July 2020 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total – Mon. Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

1. The above violation is a result of an operator error. One of our WAS pumps was left running for 24 hours before it was discovered. In that time, the biomass from the secondary clarifier was depleted. The plant recovered and was back in compliance within a couple of days.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in black ink, appearing to read "S Mallett", is written over a light blue horizontal line.

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com