



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

August 13, 2021

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for July 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total – Mon. Avg. Con.
2. Coliform, Fecal – (30-Day) Avg. Geo.
3. Coliform, Fecal – Max. 7-Day Geo.
4. BOD, Carbonaceous (5-Day) – Mon. Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Occasional slug loading and plant loading throughout the month of July that inhibited the nitrification/denitrification processes in our aeration basins. The PCW has since recovered and is back in compliance.

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com