



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

April 13, 2021

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for March 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – Max. 7-Day Avg. Con.
4. Nitrogen, Ammonia Total – Mon. Avg. Loading
5. Nitrogen, Ammonia Total – Mon. Avg. Con.
6. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.
7. BOD, Carbonaceous (5-day) – Mon. Avg. Con.
8. BOD, Carbonaceous (5-day) – Mon. Avg. Con.
9. BOD, Carbonaceous (5-day) – Max. 7-Day Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- The above TSS violations are related to our secondary clarifiers washing out due to poor settling sludge blankets and increased flows from local rain events.
- The above Ammonia and BOD violations are related to slug loading that has inhibited the denitrification process in our aeration basins throughout the month of March. Our Pretreatment department suspects quaternary ammonium compounds (QAC's) and has notified local industries of this occurrence and has formulated a sampling plan in efforts to locate the source.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Manager at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett
Chief Executive Officer
City Corporation

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com