



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

June 17, 2019

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for May 2019 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Nitrogen, Ammonia – Mon. Avg. Loading
4. Nitrogen, Ammonia – Mon. Avg. Con.
5. Fecal Coliform Bacteria (FCB) – Mon. Avg.
6. Fecal Coliform Bacteria (FCB) – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above violations occurred due to increase in flow to the plant from local heavy rains in the area. The total rainfall (recorded at the plant) for the month of May equaled 7.65 inches. The plant quickly recovered and was in compliance after the rain event and has remained in compliance since that time.



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File