



P. 479-968-2105  
F. 479-968-3265

***"Award Winning Water"***

June 9, 2021

Ms. Christina Brown  
Enforcement Analyst  
Water Division/Enforcement Branch  
Division of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for May 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – Max. 7-Day Avg. Con.
4. Coliform, Fecal – Max. 7-Day Geo.
5. BOD, Carbonaceous (5-Day) – Mon. Avg. Loading
6. BOD, Carbonaceous (5-Day) – Mon. Avg. Con.
7. BOD, Carbonaceous (5-Day) – Max. 7-Day Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Heavy local rain events throughout the month of May and high flow through the plant that led to our biomass washing out of our secondary clarifiers.

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Manager at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett  
Chief Executive Officer

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com