



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

June 13, 2022

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for May 2022 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – Max. 7-Day Geo. Con.
4. Nitrogen, Ammonia Total – Mon. Avg. Loading
5. Nitrogen, Ammonia Total – Mon. Avg. Con.
6. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.
7. BOD, Carbonaceous (5-Day) – Mon. Avg. Loading
8. BOD, Carbonaceous (5-Day) – Mon. Avg. Con.
9. BOD, Carbonaceous (5-day) – Max. 7-Day Avg. Con.
10. Dissolved Oxygen (DO) – Inst Min.
11. Mercury, Total Recoverable – Mon Avg. Loading
12. Mercury, Total Recoverable – Mon Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- All the above permit violations occurred during the first two weeks of the month. During this period heavy rains caused increased flow to the plant and the continue construction activities limited the plant's ability to handle the flow and provide the necessary treatment. The plant has recovered as of May 18, 2022, and is currently within permit limits.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett
Chief Executive Officer
City Corporation