



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

November 12, 2021

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for October 2021 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Coliform, Fecal – Mon. Avg. Con.
2. Coliform, Fecal – 7-Day Max. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- A slug load came through the evening of 11/18 that made our DOs in our aeration basin drop under 2.00 from 6pm to 12am 11/19 before they started rising again. It also showed in our PAA contact basin residual which inhibited the disinfection process. The PCW has since recovered and is back in compliance.

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com