



P. 479-968-2105  
F. 479-968-3265

*"Award Winning Water"*

May 11, 2022

Ms. Christina Brown  
Enforcement Analyst  
Water Division/Enforcement Branch  
Division of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for April 2022 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Loading
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – Max. 7-Day Geo. Con.
4. Nitrogen, Ammonia Total – Mon. Avg. Loading
5. Nitrogen, Ammonia Total – Mon. Avg. Con.
6. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.
7. BOD, Carbonaceous (5-Day) – Mon. Avg. Loading
8. BOD, Carbonaceous (5-Day) – Mon. Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Again, local heavy rainfall, increased flow through the plant, and the nitrification/denitrification process in our aeration basins still not functioning properly for treatment. The PCW is still operating with one of three secondary clarifiers offline and one of three aeration basins offline due to permitted construction improvements. The staff continues its efforts to get the PCW back into compliance as soon as possible while construction is ongoing.

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com



P. 479-968-2105  
F. 479-968-3265

***"Award Winning Water"***

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett  
Chief Executive Officer

205 W. 3rd Place  
PO Box 3186  
Russellville, AR 72811  
citycorporation.com