



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

September 20, 2023

Ms. Kristen Graham
Compliance Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Graham:

This letter shall serve as the noncompliance report (NCR) for August 2023 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Peracetic Acid - Inst. Max.
2. Nitrogen, Nitrate Total – Monthly Avg.
3. Nitrogen, Nitrate Total – 7-Day Avg.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- The PCW experienced PAA pump issues. This forced operators to dose from a one-way valve chemical tote with no real way to monitor dosage rate until the pump issues were fixed.
- The nitrate violations had multiple variables that contributed to noncompliance: a decrease in BOD loading at times, equipment issues that directly affected anoxic zones (denitrification) and increased influent ammonia throughout the month of August.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,


Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com