



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

March 26, 2024

Ms. Rachel Wilcox
Compliance Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Wilcox:

This letter shall serve as the noncompliance report (NCR) for February 2024 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total (as N) – Mon. Avg. Con.
2. Nitrogen, Ammonia Total (as N) – 7-Day Avg. Max
3. Peracetic Acid – Inst. Max
4. Coliform, Fecal – 7-Day Avg. Max

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- There was a reoccurring equipment issue in one of the four aeration basins throughout the month of February. This hindered the nitrification/denitrification process and the ability for that basin to hold an effective treatment environment. The PAA violation was due to an effluent flow meter malfunction that caused the PAA pump (flow based) to dose higher than necessary. Our fecal coliform violation was due to a difference in metering pumps. We discovered one metering pump dosed more evenly than the second. We have corrected these issues and the PCW is back in compliance.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,


Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com