



P. 479-968-2105

F. 479-968-3265

"Award Winning Water"

February 22, 2024

Ms. Rachel Wilcox
Compliance Analyst, Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Wilcox:

This letter shall serve as the noncompliance report (NCR) for January 2024 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total (as N) – Mon. Avg. Load.
2. Nitrogen, Ammonia Total (as N) – Mon. Avg. Con.
3. Nitrogen, Ammonia Total (as N) – 7-Day Avg.
4. Coliform, Fecal – Mon. Avg. Con.
5. Coliform, Fecal – 7-Day Avg.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Suspected slugs from a local industry that hindered the nitrification ability of the biomass. Local heavy rain events and extreme cold weather throughout the month of January. The plant also had one of three secondary clarifiers and one of four aeration basins out of service due to equipment issues. We suspect the extreme temperature and possible interference in the water affected the peracetic acids (PAA) ability to properly disinfect our effluent, which lead to increased fecal coliform counts. The PCW has been back in compliance since these events.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,

A handwritten signature in blue ink, appearing to read "Steve Mallett", is written over a white background.

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com