



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

April 12, 2022

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for March 2022 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total – Mon. Avg. Loading
2. Nitrogen, Ammonia Total – Mon. Avg. Con.
3. Nitrogen, Ammonia Total – Max. 7-Day Avg. Con.
4. Coliform, Fecal – Max. 7-Day Geo. Con.
5. BOD, Carbonaceous (5-Day) – Mon. Avg. Loading
6. BOD, Carbonaceous (5-Day) – Mon. Avg. Con.
7. BOD, Carbonaceous (5-Day) – Max. 7-Day Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Local heavy rainfall and the nitrification/denitrification process in our aeration basins not working properly for treatment. The PCW is still operating with one of three secondary clarifiers offline and one of three aeration basins offline due to construction improvements. The staff continues its efforts to get the PCW back into compliance as soon as possible while construction improvements are ongoing.

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

Should you have any questions or need other info please contact Randy Bradley, Wastewater Operations Director at 479-968-2080 ext. 224.

Sincerely,

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com