



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

December 6, 2017

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for November 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. pH - Min.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The pH violation occurred on Monday following the Thanksgiving holiday. It is our belief that due to reduced flow and loading from our major industrial customer, the pH and alkalinity was lower than normal. Plant operators added some bags of lime to the aeration basins and the pH was back within permit limits within the hour. We have stored additional lime on site for the upcoming Christmas break in efforts to prevent a similar occurrence.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com