



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

November 7, 2017

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for October 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Coliform, Fecal – 7-day Geo Avg.

The above violation was caused by the following events at the Pollution Control Works during this reporting period.

1. The fecal coliform violation occurred due to a leak in a chlorine solution line. The chlorine solution line that feeds final basin #2 runs underground and had developed a leak, this leak prevented the chlorine solution from getting to the basin. Once the leak was found and repaired the plant was back in compliance that afternoon.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in blue ink, appearing to read "S. Mallett", is written over a light blue horizontal line.

Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com