



# CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Phone (479) 968-2105  
FAX (479) 968-3265

April 22, 2013

Alan Anderson  
NPDES Enforcement Section  
Arkansas Department of Environmental Quality  
5301 North Shore Dr  
North Little Rock, Arkansas 72118

RE: Storm water Blending April 10, 2013 thru April 14, 2013  
Russellville City Corporation Pollution Control Works  
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Wednesday April 10, 2013 and ending Sunday April 14, 2013. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 18,606,500 gallons estimated.

Wednesday, April 10, 2013

Total Suspended Solids	136.0 mg/l	CL2	0.02 mg/l
Dissolved Oxygen	6.0 mg/l	pH	6.81
Ammonia	7.86 mg/l	BOD	>47.1 mg/l
Fecals	1,450/100ml		

Thursday, April 11, 2013

Total Suspended Solids	248.0 mg/l	CL2	0.02 mg/l
Dissolved Oxygen	5.7 mg/l	pH	6.37
Ammonia	7.21 mg/l	BOD	>45.3 mg/l
Fecals	9,400/100ml		

Friday, April 12, 2013


Total Suspended Solids	68.0 mg/l	CL2	0.09 mg/l
Dissolved Oxygen	6.85 mg/l	pH	6.37
Ammonia	4.02 mg/l	BOD	43.5 mg/l
Fecals	5,500/100ml		

Sincerely,

Steve Mallett  
General Manager

cc: Ricky Biffle  
Randy Bradley  
File

CERTIFIED MAIL™



7011 0110 0001 6831 3012

LACE  
11-3186

neopost  
04/23/2013

US POSTAGE

\$06.25<sup>00</sup>



ZIP 72801  
041L11235277

ADEQ  
5301 North Shore Drive  
North Little Rock, AR 72118

Attn: Alan Anderson

72118531799

