



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105
Fax (479) 968-3265

January 5, 2016

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for December 2015 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Total Residual Chlorine (TRC) – Inst. Max.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The TRC violation was a result of defective analysis equipment used to monitor and regulate the sulfur dioxide system. City Corporation has contracted engineering firm to evaluation our current system and develop corrective actions to ensure the system functions correctly. During the period of study and corrections, operators will operate system in manual and monitor to ensure compliance with permit requirements.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in black ink, appearing to read 'Steve Mallett', written over a light blue horizontal line.

Steve Mallett
General Manager

cc: Larry Collins
Randy Bradley
File