

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): May 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions						
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location			
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)			
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch			
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet			
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	GR-Ground Surface			
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area			
		HR-Hand Rodded	CB-Contained in Building			
		EN-Referred to Engineering				
		PN-Public Notification				

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
4th St & S Arlington	1334	5/11/2015	5/11/2015	8,975	R	NEAH	EC	PA
1300 Blk N Glenwood	2815	5/11/2015	5/11/2015	8,550	R	NEAH	EC	GR
615 N Greenwich	1725	5/11/2015	5/11/2015	730	R	NEAH	EC	PA
1300 Blk N Glenwood	2816	5/11/2015	5/11/2015	8,250	R	NEAH	EC	GR
1700 Blk N Glenwood	2817	5/11/2015	5/11/2015	8,525	R	NEAH	EC	GR
1300 Blk N Glenwood	1466	5/11/2015	5/11/2015	8,400	R	NEAH	EC	GR
N Glenwood & O St	2050	5/11/2015	5/11/2015	7,750	R	NEAH	EC	GR/DI
1600 Blk N Glenwood	2048	5/11/2015	5/11/2015	17,250	R	NEAH	EC	GR
E 11th & S Boston	5032	5/11/2015	5/11/2015	1,120	R	NEAH	EC	PA
2005 E Main	4009	5/10/2015	5/10/2015	4,450	R	NEAH	EC/HC	PA/DR


Signature of Cognizant or Ranking Official **Date** 6-8-15

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Civ Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): May 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions			
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	DR-Drop Inlet
RO-Roots	V-Vandalism	HC-Hydro Cleaned	GR-Ground Surface
		HR-Hand Rodded	PA-Paved Area
		EN-Referred to Engineering	PA-Paved Area
		PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
407 N Arkansas	6" CO	5/10/2015	5/13/2015	181,850	R	NEAH	EC	DI
1002 E I St	4078	5/11/2015	5/12/2015	7,510	R	NEAH	EC	PA/GR
1611 E Main St	4019	5/11/2015	5/11/2015	1,350	R	NEAH	HC	DI
John Trusty Ln	3191	5/10/2015	5/12/2015	22,000	R	NEAH	EC	DI/CR-Lake Dardanelle
S Vancouver & 3rd Ct	1315	5/10/2015	5/12/2015	13,860	R	NEAH	EC	PA
W 4th and S Waco	1333	5/11/2015	5/12/2015	218,250	R	NEAH	EC	DR
2807 N Arkansas	2024	5/10/2015	5/13/2015	185,250	R	NEAH	EC	CR/DI/GR-Prairie
1819 E Main St	4021	5/11/2015	5/11/2015	370	R	NEAH	HC	GR
220 Lakefront Dr	2035	5/17/2015	5/17/2015	17,050	R	NEAH	EC	CR-Prairie
2807 N Arkansas	2024	5/17/2015	5/18/2015	193,050	R	NEAH	EC	CR/DI/GR- Prairie

 Signature of Cognizant or Ranking Official

6-8-15 Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): May 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	GR-Ground Surface
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area
		HR-Hand Rodded	CB-Contained in Building
		EN-Referred to Engineering	
		PN-Public Notification	

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
E G St & N Greenwich	1725	5/17/2015	5/17/2015	600	R	NEAH	EC	PA
John Trusty Ln	3191	5/17/2015	5/18/2015	304,250	R	NEAH	EC	DI/GR
3rd Ct & S Vancouver	1315	5/17/2015	5/17/2015	6,045	R	NEAH	EC	DI/PA
407 N Arkansas	4" Line	5/17/2015	5/17/2015	8,575	R	NEAH	EC	CR-Prairie
1815 N El Paso Ave	2043	5/20/2015	5/20/2015	20,800	R	NEAH	EC	DI/GR
Hilltop & Marina Rd	3273	5/20/2015	5/20/2015	1,325	R	NEAH	EC	DI
E 10th St & S Glenwood	5121	5/20/2015	5/20/2015	450	R	NEAH	EC	DI
E G St & N Greenwich	1725	5/20/2015	5/20/2015	6,700	R	NEAH	EC	DI/DR/PA
1300 N Glenwood	2816	5/20/2015	5/20/2015	5,075	R	NEAH	EC	DI/GR
220 Lakefront Dr	2036	5/20/2015	5/21/2015	64,900	R	NEAH	EC	GR/CR/DI-Lake Dardanelle

[Signature]
Signature of Cognizant or Ranking Official

6-8-15
Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): May 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions								
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location					
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)					
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch					
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet					
R-Rainfall	RG-Roots / Grease	HR-Hand Rodded	GR-Ground Surface					
RO-Roots	V-Vandalism	EN-Referred to Engineering	PA-Paved Area					
		PN-Public Notification	CB-Contained in Building					
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
John Trusty Ln	3191	5/20/2015	5/21/2015	256,400	R	NEAH	EC	GR
W Birch & I-40	2024	5/20/2015	5/22/2015	545,000	R	NEAH	EC	D/GR
3rd Ct & S Vancouver	1315	5/20/2015	5/20/2015	28,050	R	NEAH	EC	DR
1600 Blk N Glenwood	2048	5/20/2015	5/20/2015	20,700	R	NEAH	EC	GR
N Glenwood & O St	2050	5/20/2015	5/20/2015	30150	R	NEAH	EC	D/GR
407 N Cumberland	3043	5/20/2015	5/20/2015	1440	R	NEAH	EC	GR
404 Jimmy Lile Rd	8048	5/20/2015	5/20/2015	97500	R	NEAH	EC	D/GR/CR-Whig
11th & S Boston	5032	5/20/2015	5/20/2015	22050	R	NEAH	EC	D/PACR
W 4th and S Waco	1333	5/20/2015	5/20/2015	9250	R	NEAH	EC	DR
407 N Arkansas	4" Line	5/26/2015	5/27/2015	138,400	R	NEAH	HC/EC	CR- Prairie


Signature of Cognizant or Ranking Official 6-8-15
Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): May 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions								
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location					
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)					
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch					
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet					
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	GR-Ground Surface					
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area					
		HR-Hand Rodded	CB-Contained in Building					
		EN-Referred to Engineering						
		PN-Public Notification						
Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
W Birch & I-40	2033	5/26/2015	5/27/2015	33,575	R	NEAH	HC/EC	DI/GR
407 N Arkansas	4" Line	5/30/2015	6/1/2015	67,500	R	NEAH	HC/EC	CR- Prairie
W Birch & I-40	2033	5/30/2015	5/31/2015	30,750	R	NEAH	HC/EC	DI/GR


 Signature of Cognizant or Ranking Official Date 6-8-15

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."